



水務署
Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong.

電子郵件 wsdinfo@wsd.gov.hk
e-mail

電話 2829 4367
Telephone

圖文傳真 2824 0578
Facsimile

檔號 (4) in WSD 3321/15 Pt.1 T/J(564)
Reference

10 December 2015

E & I International Limited
8/F., Block B, Chung Mei Centre,
15 Hing Yip Street, Kwun Tong,
Hong Kong

(Attn.: Ms Crystal KWAN)

Dear Madam,

Approval of “Bellini” Single Lever Wash Basin Mixer

Your letter ref. CY20151110A dated 11 November 2015 refers.

Having considered test reports ref. 154310ST150814 issued on 10 November 2015 by Fugro Technical Services Limited, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: E & I International Limited

Country of Origin: China

Brand: Bellini

Details of Fittings: 3/8" Single Lever Wash Basin Mixer

Model: BL/XX00/YY
(where XX denotes the code of handle, YY denotes the code of finish)

Body Markings: Logo of Bellini on body

Expiry Date: 24 September 2020

This Authority hereby permits the use of the above fittings in fresh water plumbing systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following requirement-

“The cold water supply to the fittings shall be drawn from the same source that supplies the hot water apparatus so as to provide a balanced pressure and to obviate the risk of scalding in the event of a restriction or failure in the water supply.”

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in fresh water plumbing systems.

This acceptance is only applicable to the main body of the fitting, unless other specified.

For the use of the fittings in any project, the Acceptance Reference Number at the bottom of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Ms. K L FOK at tel. no. 2829 5657.

Yours faithfully,



(LAM Ching Man)
for Water Authority

c.c. WSD 3321/1/82] - without catalogue
 E/CS(TS)1]



自願參與用水效益標籤計劃 - 水龍頭
Voluntary Water Efficiency Labelling Scheme - Water Taps

Certificate of Registration
註冊證書


茲證明

This is to certify that

E&I International Limited

將下列水龍頭在本計劃內註冊：
has registered the following water tap under this scheme :

牌 子 / Brand	:	Bellini
型 號 / Model	:	BL/8800/CR
種 類 / Type	:	Mixing
原產地 / Country or Region Origin	:	China

在用水效益標籤上展示的標誌 <i>Symbolic Presentation on the Water Efficiency Label</i>	:		滴水點 <i>Water droplet(s)</i>
用水效益級別 <i>Water Efficiency Grade</i>	:	1	
耗水量 <i>Water Consumption</i>	:	3.2	公升/分鐘 <i>litres/minute</i>

簽發日期： 15 June 2016
Date of Issue:

 水務署
Water Supplies Department



水務署署長(梁中立代行)
for Director of Water Supplies