



水務署

Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong

電子郵件
e-mail wsdinfo@wsd.gov.hk

電話
Telephone 2829 4367

圖文傳真
Facsimile 2824 0578

檔號
Reference (2) in WSD 3321/15 Pt.1 T/J(710)

11 January 2016

E & I International Limited
8/F, Block B
Chung Mei Centre
15 Hing Yip Street, Kwun Tong
Kowloon, Hong Kong

(Attn.: Ms Crystal KWAN)

Dear Madam,

Approval of "BELLINI" Sensor Flush Valves for Urinals

Your letter ref. CY20151218A dated 18 December 2015 refers.

Having considered test report ref. 154312ST150797 issued on 16 Dec 2015 by the Fugro Technical Services Limited, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: E & I International Limited

Country of Origin: China

Brand: Bellini

Details of Fittings: 1" Urinal sensor flush valve (AC & DC)

Model: BL-GL-8688 & BL-GL-8688A

Body Markings: Bellini

Expiry Date: 17 November 2020

Proviso: As the fittings have not been tested for use in contact with water intended for human consumption, the fittings can only be used in flushing water plumbing system.

This Authority hereby permits the use of the above fittings in flushing water plumbing systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following requirement-

“Installation of filters before flushing valves is required. Without the filters, the flushing valves are liable to leak. The installed filters need frequent inspection and cleaning to maintain flushing supply. Normally only public toilets with good management system for maintenance would be considered.”

“A stop cock or gate valve must be installed at the upstream of the fittings for manual isolation of water supply.”

“The design flushing volume of the flushing valves should be compatible with the toilet bowl to ensure that effective clearance can be achieved by a single flush of water.”

“Flushing valves should be used within the range of working pressures specified by the manufacturer.” AND

“Installation of electronic opening and closing sanitary tapware should also comply with the requirements of Electrical & Mechanical Services Department.”

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fail to meet that of the approved samples or if the fittings are found to be unsuitable for use in flushing water plumbing systems.

For the use of the fittings in any project, the Acceptance Reference Number at the bottom of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Yours faithfully,



(LAM Ching Man)
for Water Authority

c.c. WSD 3321/1/82] - without catalogue
E/CS(TS)1]

註冊號碼 (Registration No.): 1U 16-0001



自願參與用水效益標籤計劃 - 小便器用具 Voluntary Water Efficiency Labelling Scheme - Urinal Equipment

Certificate of Registration

註冊證書

茲證明

This is to certify that

E&I International Limited

將下列小便器用具在本計劃內註冊：
has registered the following urinal equipment under this scheme:

牌子 / Brand	:	Bellini
型號 / Model	:	BL-GL-8688
種類 / Category	:	1
原產地 / Country or Region Origin	:	China

在用水效益標籤上展示的標誌

Symbolic Presentation on the Water Efficiency Label : 

滴水點

Water droplet(s)

用水效益級別

Water Efficiency Grade : 1

沖水量

Water Flush Volume : 0.8

公升/循環

litres/cycle

簽發日期：
Date of Issue: 20 April 2016



水務署
Water Supplies Department



水務署署長(梁中立代行)

for Director of Water Supplies

* 上述小便器用具具有智能功能，並且能達至額外節省用水。

The above urinal equipment is operated with a smart demand operation to achieve additional water saving.