



水務署

Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong

電子郵件
e-mail wsdinfo@wsd.gov.hk

電話
Telephone 2829 4355

圖文傳真
Facsimile 2824 0578

檔號
Reference (2) in WSD 3321/17 Pt.1 T/J(23)

9 February 2017

E&I International Limited
8/F., Block B, Chung Mei Centre,
15 Hing Yip Street, Kwun Tong,
Kowloon, Hong Kong

(Attn.: Ms Fanny YAU)

Dear Madam,

Approval of "BELLINI" Sensor Flush Valve

Your letter ref. FY170109A dated 9 January 2017 refers.

Having considered the test report ref. J21126A issued on 6 January 2017 by Nutek Systems (HK) Limited, this Authority accepts that the fitting described below complies with, and its use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: E&I International Limited

Country of Origin: China

Brand: Bellini

Details of Fitting: 1/2" Urinal sensor flush valve

Model: BL/GL-8688B

Body Markings: 

Expiry Date: 3 January 2022

Proviso: As the fitting has not been tested for use in contact with water intended for human consumption, the fitting can only be used in flushing water plumbing system.

This Authority hereby permits the use of the above fitting in flushing water plumbing systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following requirement-

“Installation of filter before flushing valve is required. Without the filter, the flushing valve is liable to leak. The installed filter need frequent inspection and cleaning to maintain flushing supply. Normally only public toilets with good management system for maintenance would be considered.”

“A stop cock or gate valve must be installed at the upstream of the fitting for manual isolation of water supply.”

“The design flushing volume of the flushing valve should be compatible with the toilet bowl to ensure that effective clearance can be achieved by a single flush of water.”

“Flushing valve should be used within the range of working pressures specified by the manufacturer.” AND

“Installation of electronic opening and closing sanitary tapware should also comply with the requirements of Electrical & Mechanical Services Department.”

A condition of this acceptance is that the fitting to be installed shall be replicas of the sample as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fitting installed fails to meet that of the approved sample or if the fitting is found to be unsuitable for use in flushing water plumbing systems.

For the use of the fitting in any project, the Acceptance Reference Number at the bottom of this letter must be quoted as a means of identification of acceptance of the fitting by this Authority.

Should you have any enquiries, please contact our Engineer Mr Terry KUNG at tel. no. 2294 2656.

Yours faithfully,



(CHAN Chung Kun)
for Water Authority

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only

註冊號碼 (Registration No.): 1U 17-0003



自願參與用水效益標籤計劃 - 小便器用具 Voluntary Water Efficiency Labelling Scheme - Urinal Equipment

Certificate of Registration

註冊證書

茲證明

This is to certify that

E&I International Limited

將下列小便器用具在本計劃內註冊：
has registered the following urinal equipment under this scheme:

牌子 / Brand	:	Bellini
型號 / Model	:	BL/GL-8688B
種類 / Category	:	1
原產地 / Country or Region Origin	:	China

在用水效益標籤上展示的標誌

Symbolic Presentation on the Water Efficiency Label



滴水點

Water droplet(s)

用水效益級別

Water Efficiency Grade

: 1

沖水量

Water Flush Volume

: 1.5

公升/循環

litres/cycle

簽發日期:

Date of Issue:

12 June 2017



水務署

Water Supplies Department



水務署署長(周世威代行)

for Director of Water Supplies

* 上述小便器用具具有智能功能，並且能達至額外節省用水。

The above urinal equipment is operated with a smart demand operation to achieve additional water saving.