



水務署

Water Supplies Department

香港灣仔告士打道七號入境事務大樓

Immigration Tower, 7 Gloucester Road, Hong Kong.

電子郵件  
e-mail

wsdinfo@wsd.gov.hk

電話 2829 4367

Telephone

圖文傳真 2824 0578

Facsimile

檔號 (2) in WSD 3321/11 Pt.1 T/J(192)

Reference

23 August 2011

E & I International Limited  
9/F., Wing Tai Centre, 12 Hing Yip Street,  
Kwun Tong, Kowloon,  
Hong Kong.

(Attn.: Ms. Fanny YAU)

Dear Sirs,

### Approval of "Bellini" Bath/Shower Mixer

Your letter ref. FY110815A dated 15 August 2011 refers.

Having considered the test report by the Nutek Systems, Ltd., this Authority accepts that the fitting described below comply with, and its use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

**Name of Manufacturer:** E & I International Limited

**Country of Origin:** China

**Brand:** Bellini

**Details of Fitting:** ½" Single lever concealed bath/shower mixer (no internally applied metallic coating).  
Model no.: FXX68G04  
(where XX denotes the code of handle; QN, 15, 38, 36, 84, 85, 88 and 47)

This Authority hereby permits the use of the above fitting in fresh water plumbing systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following requirements-

"The cold water supply to the fitting shall be drawn from the same source that supplies the hot water apparatus so as to provide a balanced pressure and to obviate the risk of scalding in the event of a restriction or failure in

the water supply.”

And

“Any shower head to be connected to the mixer should not be placed in submerged conditions and should be securely fixed to the original position after use.”

A condition of this acceptance is that the fitting to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fitting installed fails to meet that of the approved samples or if the fitting is found to be unsuitable for use in fresh water plumbing systems.

For the use of the fittings in any project, the Acceptance Reference Number at the bottom of this letter must be quoted as a means of identification of acceptance of the fitting by this Authority.

Yours faithfully,



(CHIN Chu Sum)  
for Water Authority

